



LEGEND OF FIRE FIGHTING SYSTEM	
FIRE EXTINGUISHER	☉
MANUALLY OPERATED ELECTRONIC FIRE ALARM	M.O.E.F.A.
AUTOMATIC SPRINGLAR SYSTEM	☉
AUTOMATIC DETECTION & ALARM SYSTEM	☉
U.G. WATER TANK- 50000 LT.	U.G.
TARESS TANK- 10000 LT.	O.T.
FIRST AID HOSEREEL	☉
ONE ELECTRICAL PUMP- 450 LPM	E.P.
ONE DIESEL PUMP-450 LPM	D.P.
ONE JOCKEY PUMP-180 LPM	J.P.
SAND BUCKETS	☉
DELIVERY HOSE BOX	D.H.B.
FIRE HYDRANT	☉

AREA STATEMENT	MT.
TOTAL PLOT AREA	10021 SQ. MT.
GROUND FLOOR COVERED AREA	1318.0 SQMT.
FIRST FLOOR COVERED AREA	1318.0 SQMT.
SECOND FLOOR COVERED AREA	1318.0 SQMT.
TOTAL FLOOR COVERED AREA	3954.0 SQMT.
OPEN PLOT AREA	8703.0 SQMT.
MUMTY	68.0 SQ. MT.
TOTAL F.A.R.	1.2%
FRONT MAIN ROAD- 10.0 MT. WIDE	
DOOR WINDOW DETAILS	
DOOR	WINDOW
D-- 1.25 X 2.13	W-- 1.5 X 1.5
D1 - 0.75 X 1.82	V -- 0.45 X 0.60
CAMPUS MAIN ENTRY GATE - 6.0 MT. WIDE	
CERTIFIED THAT TIS BUILDING PLAN HAS BEEN PREPARE AS BUILDING BY IS-456-2000 COAD	
FIRE SAFTY NORMS	
FIRE SAFTY WORKS AS PER N.B.C. 2016	
TOP SLAB FLOOR HIGHT-	
GROUND FLOOR- 3.50 MT.	
FIRST FLOOR- 3.00 MT.	
SECOND FLOOR- 3.00 MT.	
TOTAL HIGHT -PLINTH TO TARESS- 9.50 MT.	

EXISTING EDUCATIONAL BUILDING PLAN OF  
**R.R. MAHAVIDYALYA**  
 ARAZI NO-1175,1176,1177,1178,  
 1218,1219,1220,1221,1222,1223  
 VILLAGE-BAJALPUR , AMARGARH  
 PRATAPGARH

SIGN OF OWNER	APPROVAL BY
Drawn by- Er. VAJAY KUMAR 6387032677 ARCHITECTURE, CIVIL/INTERIER CONSULTING ENGINEER JAUNPUR c.e.u.p.06/06-19	